

Specification G-5301
Issue: Client Comments, Rev. 3
September 8, 2011
Project No. 12681-006

SECTION 230513

COMMON MOTOR REQUIREMENTS FOR HVAC EQUIPMENT

PART 1 – GENERAL

PART I - GENERAL		
101.	GENERAL	
101.1	This section address the motor requirements for HVAC Equipment furnished and installed by the CONTRACTOR.	
101.2	CONTRACTOR shall furnish local motor starters with external disconnect switches for the HVAC Equipment.	
102.	RELATED SECTIONS	
102.1	Section 233400 HVAC Fans	
102.2	Section 262950 Low Voltage Motors	
103.	REFERENCES	
103.1	Related standards, Specifications, manuals and/or other publications of nationally recognized organizations are referenced herein. Methods, Equipment and materials shall comply with applicable or specified portions of referenced documents, in addition to Federal, State or local Codes having jurisdiction.	
103.2	References to these documents shall be to the issue date as adopted in IBC 2006. If the document is not referenced in IBC 2006, then the reference is to the latest issue date of the document together with the latest additions, addenda, amendments, supplements, etc. in effect on the date of Contract award.	
103.3	American Society Heating, Refrigerating, and Air Conditioning Engineers	
	ASHRAE 90.1, Energy Standard for Buildings Except for Low-Rise Residential Buildings	
104	SUBMITTALS	

104. <u>SUBMITTALS</u>

Submittals shall be in accordance with the requirements contained in Section 262950 'Low Voltage Motors'

PART 2 – PRODUCTS

201.	MOTORS

- The low voltage motors furnished for the HVAC equipment shall meet the requirements contained in Division 26.
- The low voltage motors furnished for the HVAC equipment shall meet the performance and efficiency requirements of ASHRAE 90.1.

230513-1



Specification G-5301
Issue: Client Comments, Rev. 3
September 8, 2011
Project No. 12681-006

PART 3 – EXECUTION

301. <u>INSTALLATION</u>

Install the motors in accordance with the manufacturer's installation instructions.

END OF SECTION 230513